

Annual Drinking Water Quality Report for 2014
Highland Water District
12 Church Street,
Highland NY
(Public Water Supply ID#NY5503368)

INTRODUCTION

To comply with State regulations, the Highland Water District, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Adam Litman, Water & Sewer Administrator, (845)691-2400. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled town board meetings. The meetings are held on the second Wednesday of the month, at Town Hall, 12 Church Street, Highland, NY 12528.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water sources are the Hudson River and four upland reservoirs. One horizontal and three vertical wells, drilled into Illinois Mountain are used as supplemental sources for the reservoirs. The reservoirs and wells are located behind the John Jankiewicz Water Plant at 2 Thomas Rizzo Boulevard, Highland NY 12528. During 2013, our system did not experience any restriction of our water source. The water is chemically conditioned, clarified, filtered, and chlorinated prior to distribution.

FACTS AND FIGURES

Our water system serves approximately 5,000 people through 1,650 service connections. The total water produced in 2014 was 165,879,739 gallons. The amount of water delivered to customers was 139,342,927 gallons. The daily average of water treated and pumped into the distribution system was 454,465 gallons, with the highest single day at 798,700. This leaves 9,439,812 gallons unaccounted for. Flushing water mains, fighting fires, water main breaks, leakage and unmetered usage, road

cleaning, and state contractor usage account for the remaining 9,439,812 gallons (6% of the total amount produced).

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Ulster County Health Department at (845) 340-3010.

| Table of Detected Contaminants | | | | | | | |
|--------------------------------|------------------|----------------|----------------------------------|------------------|------|----------------------------------|--------------------------------|
| Contaminant | Violation Yes/No | Date of Sample | Level Detected (Avg/Max) (Range) | Unit Measurement | MCLG | Regulatory Limit (MCL, TT or AL) | Likely Source of Contamination |

MICROBIOLOGICAL CONTAMINANTS

| | | | | | | | |
|------------------------|----|----------|----------|-----|-----|-----------------------|-------------|
| Turbidity ¹ | No | 1/7/14 | 0.45 Max | NTU | N/A | TT= \leq 1.0 NTU | Soil Runoff |
| Turbidity ¹ | No | 12/31/14 | 0.15 Avg | NTU | N/A | TT=95% \leq 0.3 NTU | Soil Runoff |

DISINFECTION BY-PRODUCTS

| | | | | | | | |
|-------------------------------------|----|------|---------|------|-----|---------|---------------------|
| Total Trihalomethanes ₄ | No | 2014 | 62 Avg. | ug/l | N/A | 80 ug/l | Chlorine by-product |
| Total Haloacetic Acids ₄ | No | 2014 | 20 Avg. | ug/l | N/A | 60 ug/l | Chlorine by-product |

INORGANIC CONTAMINANTS

| Contaminant | Violation Yes/No | Date of Sample | Level Detected (Avg/Max) (Range) | Unit Measurement | MCLG | Regulatory Limit (MCL, TT or AL) | Likely Source of Contamination |
|-----------------------|------------------|----------------|----------------------------------|------------------|------|----------------------------------|----------------------------------|
| Barium | No | 8/7/14 | 0.010 | mg/l | 2.0 | 2.0 mg/l | Erosion of natural deposits |
| Chloride | No | 2014 Avg | 38 | mg/l | N/A | 250 mg/l | Naturally occurring |
| Nitrate-Nitrogen | No | 8/7/14 | 0.32 | mg/l | N/A | 1.0 mg/l | Naturally occurring |
| Sulfate | No | 8/29/13 | 10 | mg/l | N/A | 250 mg/l | Naturally occurring |
| Sodium | No | 2014 Avg | 11.6 | mg/l | N/A | N/A | Naturally occurring |
| Lead ₃ | No | 6/14/12 | 0.005 | ug/l | N/A | AL=15 | Corrosion of household pl. |
| Copper _{4,2} | No | 6/14/12 | 0.756 | ug/l | N/A | AL=1.3 | Corrosion of household pl. |
| Chlorine Residual | No | 2014 Avg | 1.6 | mg/l | N/A | 4.0 mg/l | Micro organisms |
| Total Coliform | No | year round | Absent | CFU/100ml | | | Naturally present in environment |

1 – Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. Our highest single turbidity measurement (0.45 NTU) for the year occurred on 1/7/14. State regulations require that turbidity must always be below 1.0 NTU. The levels recorded were within the acceptable range allowed and did not constitute a treatment technique violation.

2 – The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, (include number of samples, e.g. ten samples) samples were collected at your water system and the 90th percentile value was the (include what sample had the highest value, e.g. second highest value) value (include level detected e.g. 1.1 mg/l). The action level for copper was not exceeded at any of the sites tested.

3 – The level presented represents the 90th percentile of the 22 samples collected. The action level for lead was exceeded at two of the 10 sites tested.

4 – This level represents the annual quarterly average calculated from data collected.

5 – Total Organic Carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection by-products. These include trihalomethanes (THMs) and Haloacetic Acids (HAAs).

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picograms per liter (pg/l): Corresponds to one part per of liquid to one quadrillion parts of liquid (parts per quadrillion – ppq).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers that are longer than 10 micrometers.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The Highland Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2014, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and

- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you can save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions. This report will also be available on the web at www.townoflloyd.com/water

Please contact our office at (845)691-2400 with any questions.